



Wills Bros Laboratory.

Site Laboratory
N5 Ballaghaderreen By Pass
Site Office
Sligo Road
Ballaghaderreen
Co. Roscommon
Tel. 094 9860106

Date Reported 24.03.14
Sample Ref A/ 339
Page 1 of 1
File No.

Client:

Wills Brothers
Ballaghaderreen By Pass
Sligo Road
Ballaghaderreen
Co. Roscommon
Tel. 094 9860106

Your Order No: Not Applicable.

LABORATORY TEST REPORT.

Test Requirements:

To Determine the **Methelene Blue Value (MB)** of Soil sample in accordance with BS EN 933-9 : 1999

Sample Details

Material Sampled By :	WB
Certificate of sampling received:	YES
Certificate Enclosed :	No
Laboratory Reference Number :	A/339
Client Reference Number :	N/A
Material Description :	CL804
Date of Sampling :	20.03.14
Time of Sampling :	PM
Method of Sample Reduction :	B.S 1377 pt.2 1990 (Riffle)
Sampling Location :	Harrington Kilkelly Quarry
Delivery Ticket No :	N/A
Name of Source :	Stockpile Outside Compound
Date Of Reciept in Laboratory.	20.03.14
Date of Start of Test :	24.03.14
Date of Test Completion :	24.03.14
Target Specification :	

Result - MB = 0.74 g/Kg

Comments / Departure From Specified Procedure

Specification Not Published

Approved Signatures – P.E.Johnson (Laboratory Manager)
R.Rooney(Quality Manager)