

First Of Kind Form




Pavan Talanki Manjunath
Created Mon, 31 Jul 2023, 1:43 PM (UTC+01)

First Of Kinds Acceptance Form in accordance with WB.2951.IP060.FM002

FOK Number	WB/IMS/2951/FOK/001
FOK Description	Formation for pads foundation
Date and Time Raised	Mon, 10 Jul 2023, 3:00 pm

APPROVED MATERIAL ACCEPTANCE REQUEST

MAR Number	Submittal Number (EIDA)	MAR Description
NA	NA	NA

FOK Description	FOK location	Comments	Raised by WBL	Approved by WBL	Accepted by PMG/PFIZER/JACOBS (Where required)
Formation for pad foundation	GL20.F/3	<p>Comments by ByrneLooby: A strong to medium strong fractured Limestone Bedrock was encountered at the excavated foundation formation level at Pad 20.F3. At the time of inspection, the entire foundation formation of Pad 20.F3 was scraped with a 14T track excavator and any large loose rock blocks or highly weathered zones were removed/excavated to a general level of 65.0m OD. Based on the visual inspection completed, ByrneLooby are satisfied that the strong to medium strong fractured Limestone encountered at the above formation level shall have an allowable bearing capacity of the required 500kN/m2.</p> <p>Pfizer system number :C001</p>	Pavan Talanki Manjunath	<p>Pavan Talanki Manjunath</p>  <p>Wills Bros Ltd Mon, 31 Jul 2023, 1:48 pm</p>	<p>Mark Sutton</p>  <p>Pfizer Wed, 02 Aug 2023, 10:23 am Cathal Sweeney</p>  <p>PM Group Wed, 02 Aug 2023, 10:24 am</p>

Photographs of FOK



See full page photos attached at end of PDF

No GPS information available

Captured by: Pavan Talanki Manjunath

Captured on: Mon, 31 Jul 2023, 1:03 pm

Tags:

Description:

Comments:



No GPS information available

Captured by: Pavan Talanki Manjunath

Captured on: Mon, 31 Jul 2023, 12:59 pm

Tags:

Description:

Comments:



No GPS information available

Captured by: Pavan Talanki Manjunath

Captured on: Mon, 31 Jul 2023, 12:59 pm

Tags:

Description:

Comments:

